



20098 SAN GIULIANO MILANESE - Fraz. Sesto Ulteriano - Via Lombardia, 49  
Tel. 98.80.360 - 98.80.282 / 283 / 284  
Telex: 326610 ICITEM - I

MDD. CRF 3

S. Giuliano Mil. 25/02/86

CERTIFICATO  
DI  
REAZIONE AL FUOCO



A) PRODUTTORE: SILENT GLISS CASA S.r.l  
B) DENOMINAZIONE COMMERCIALE DEL MATERIALE: COLORAMA 1 F.R. STABILUS  
C) CODICE DI IDENTIFICAZIONE DEL MATERIALE: 154/86  
D) IMPIEGO: TENDAGGIO  
E) POSA IN OPERA: SOSPESO A PARETE

In esito alle prove CSE-RF1/75/A e CSE-RF3/77  
di cui al Decreto Ministeriale 26-6-1984, Supplemento ordinario  
Gazzetta Ufficiale n. 234 del 25-8-1984 e relativamente ai cam-  
pioni presentati, al materiale denominato :

COLORAMA 1 F.R. STABILUS codice : 154/86

e attribuita la classe 1 (uno) di reazione al fuoco.

Il presente certificato e costituito da 4 pagine

REPARTO REAZIONE AL FUOCO  
IL RESPONSABILE

Dott. PierMaria Sartori



IL DIRETTORE

Dott. Ing. Claudio Cerruti

1/4

**Application for approval of the trademark  
TREVIRA®**

**Trevira**  
THE FIBRE COMPANY

Trevira GmbH  
Markenprüfung /  
Trademark Testing  
Technikum, Gebäude 515  
Max-Fischer-Straße 11  
D-86399 Bobingen

Applicant

Company	Silent Gliss Fabrics & Components GmbH
Road	Rebgartenweg 5
Post Code/City	D-79576 Weil am Rhein
Country	Germany

Name / Signature 01/02/2012

**Trademark** Trevira CS

**Article** Colorama 1

**End Use**  
Drapes  
Roller / vertical blinds

**Other uses** EN 13501

**Composition** 100% Trevira CS

**Fabric weight (g/sm)** 135

Yarn Details

**Warp**

**Yarn titre/ count** NE 28/2

**Trevira Type** 270

**Yarn supplier** Fil Man Made Group

	<b>Weft 1</b>	<b>Weft 2</b>	<b>Weft 3</b>
--	---------------	---------------	---------------

<b>Yarn titre/ count</b>	NE 28/2	--	--
--------------------------	---------	----	----

<b>Trevira Type</b>	270	--	--
---------------------	-----	----	----

<b>Yarn supplier</b>	Fil Man Made Group		
----------------------	--------------------	--	--

Approval: 26.03.2012

(This Trademark approval is valid for a period of 5 years from the date of issue).

The tested article COLORAMA 1 with application no. 120520 is granted approval for the trademark Trevira CS.

This article has been tested according to DIN 4102 part 1 and qualifies for class B1.

This article has been tested according to NF P 92-504 (Propagation of flames) and thus passes the requirements according to NF P 92-503-507, class M1.

Thus meets also the requirements according to British Standard BS 5867 part 2 type C.

This article also meets the requirements according to the Italian Standard UNI VF 8456 and UNI VF 8457, class 1.

This article qualifies for class B - s1, d0 according to the European standard EN 13501. Classification report Exova Warringtonfire, Frankfurt No. T2012-1032-K1.

26.03.12 *Mayer B*

Trevira GmbH, Trademark Service